

Prüfbericht-Nr.: ULR:TC56882040000043P
Test Report No.:

Seite 3 von 33
Page 3 of 33

Produktbeschreibung
Product description

1 Produktdetails

Product details

with 6" Poly cells

SGExxx-72P(xxx = 300-330 in steps of 1, 72 cells)

xxx represents Output power in Wp

2 Verwendete Materialien

Used materials

see Constructional Data Form in the annexure of this report

3 Adresse(n) der Fertigungsstätte(n)

Address(es) of the manufacturing site(s)

Saatvik Green Energy (P) Limited, Village Dubli, Tehsil Barara, District Ambala, Haryana – 133001,India

4 Zusammenfassung der Prüfergebnisse

Summary of test results

According to the inquiry of the customer for Reliability test requirements tests according to IEC 61215:2016 and IEC, 61730:2016, the below listed tests have been conducted on the module Type **SGE315-72P** and results were incorporated in this report: **ULR:TC56882040000043P**

1. Thermal Cycling test(200) : 600 cycles
2. UV Pre conditioning test: 45KWhm²
3. Thermal Cycling test(50) : 150 cycles
4. Humidity freeze test: 30 cycles
5. Damp heat(1000hrs): 3000hrs

This test report includes a "Zusatzdokumentation/Additional Documentation" and appendix "Foto-Dokumentation/Photo Documentation"